

**Slip Check to AS 4586:2013**  
**Natural Impressionist Replica**  
**Timber Plank - Obeidian**

**This Report Replaces Report R8663d**

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

25 May 2015

# Test Report No. R8663.1d

## Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

This Report Replaces Report R8663d

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Hurford Wholesale  
Client Address: Unit 6, 34-38 Anzac Avenue  
Smeaton Grange NSW 2567  
Product Manufacturer: Supplied by Hurford Wholesale  
Product Description: Natural Impressionist Replica Timber Plank - Obeidian

Test conducted according to: AS 4586:2013 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148  
Conducted by: Stuart Lumsden

Date: 19 May 2015      Temperature: 20°C  
Sample: Unfixed      Cleaning: None  
Rubber slider used: Slider 96      Conditioned: Grade P 400 paper dry followed by wet lapping film  
Slope of specimen: Tested on a flat level surface  
Direction of Test: With grain

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	37	32	31	33	31

<b>Reported SRV of Sample:</b>	<b>33</b>
<b>Class:</b>	<b>P2</b>



Ryan Voorderhake  
Laboratory/Field Technician