

Slip Check to AS 4586:2013
Natural Impressionist Replica
Timber Plank - Jasper

This Report Replaces Report R8663g

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

26 May 2015

Test Report No. R8663.1g

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

This Report Replaces Report R8663g

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Hurford Wholesale
Client Address: Unit 6, 34-38 Anzac Avenue
Smeaton Grange NSW 2567
Product Manufacturer: Supplied by Hurford Wholesale
Product Description: Natural Impressionist Replica Timber Plank - Jasper

Test conducted according to: AS 4586:2013 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148
Conducted by: Ryan Voorderhake

Date: 21 May 2015 Temperature: 20°C
Sample: Unfixed Cleaning: None
Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed
Slope of specimen: Tested on a flat level surface by wet lapping film
Direction of Test: With grain

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	30	30	30	30	29

Reported SRV of Sample:	30
Class:	P2



Ryan Voorderhake
Laboratory/Field Technician